

HEADER [OPTIONAL]

[DATE]

Brian Craigo
Deputy Building Official
South Central Planning and Development Commission
5058 West Main Street
Houma, LA 70360

RE: Special Inspection of Cast-in-place Deep Foundations
[PROJECT INFORMATION – Permit #]

Dear Mr. Craigo:

This letter addresses 2015 IBC Section 1704.2.4 regarding special inspections. Table 1705.8 lists inspection and testing requirements for Cast-in-place deep foundations. We have reviewed the inspection reports submitted by [XXXXXXXX] for the subject project. Based on the information contained in these reports, we note the following:

TABLE 1705.8 Item 1 – Drilling operations observed and recorded conform to the construction documents.

TABLE 1705.8 Item 2 – Foundation placement location and plumbness verified. Concrete volumes recorded.

TABLE 1705.8 Item 3- Additional special inspections verified as required for concrete elements in accordance with IBC Table 1705.3.

Based on information provided to us during the cast-in-place foundation special inspection process, as outline in IBC Table 1705.8, the foundation conforms to the design drawings and specifications as required by IBC 2015. Please give me a call if you have any questions or need additional information.

Sincerely,

[SIGNATURE BLOCK INFORMATION WITH P.E. SEAL AND SIGNATURE]